

Product Certification Schedule

Schedule No: 152/001/036

Licensee: VENTCROFT LIMITED, FARADAY ROAD, ASTMOOR INDUSTRIAL ESTATE, RUNCORN, CHESHIRE, WA7 1PE

Factory: VENTCROFT LIMITED, FARADAY ROAD, ASTMOOR INDUSTRIAL ESTATE, RUNCORN, CHESHIRE, WA7 1PE

Specification: BS 8519:2010 - Selection and installation of fire-resistant power and control cable systems for life safety and fire-fighting applications - Code of practise. Clause 11 – Category 2: means of escape (60 min survival time). Control cables meeting the PH60 classification when tested in accordance with BS 8434-2:2003+A2:2009 (core sizes up to and including 4sqmm cross-sectional area), excluding 3-phase power circuits.

Type of Cable: BS 7629-1:2008 - Electric Cables Table 1 - Multicore cables. Schedule No. 152/001/033. Meeting the enhanced fire resistant cable requirements of BS 5839-1:2013 26.2(e) tested to BS EN 50200:2006 (PH120 classification) and to BS 8434-2:2003 & A2:2009. Schedule No. 152/001/032.

HAR Document: Not applicable

HAR Specification: Not applicable

Range of Approval: 1.0sqmm to 4sqmm nominal cross-sectional area of conductors inclusive. Two-core to 4-core inclusive. Sheath LTS3. Insulation - EI2.

Origin Thread: Not applicable

Origin Mark: NOBURN PLUS

PERMISSIBLE MARKS



BASEC

YELLOW
ACETATE
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 07/12/2016

Signed for and on behalf of the British Approvals Service for Cables



Date 21/01/2014

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.



004