

## Product Certification Schedule

Schedule No: 152/001/002  
Licensee: VENTCROFT LIMITED, GODDARD ROAD, ASTMOOR INDUSTRIAL ESTATE, RUNCORN, CHESHIRE, WA7 1NQ,  
Factory: VENTCROFT LIMITED, GODDARD ROAD, ASTMOOR INDUSTRIAL ESTATE, RUNCORN, CHESHIRE, WA7 1NQ  
Specification: BS 5839-1:2002 Incorporating Amendment No.1 & A2:2008 - Fire detection and fire alarm systems for buildings - Part 1 Code of practice for system design, installation, commissioning and maintenance. Utilizing BS 7629-1:1997 Incorporating Amendment Nos. 1 & 2.  
Type of Cable: Standard requirements (PH 30) of BS 5839-1:2002 Incorporating Amendment No.1 & A2:2008  
HAR Document: Not applicable  
HAR Specification: Not applicable  
Range of Approval: 1.0sqmm to 4sqmm nominal cross-sectional area of conductors inclusive. Two-core to four-core inclusive. To BS EN 50200:2006 and Annex E of BS EN 50200:2006. Sheath - LTS3. Insulation - EI2.  
Origin Thread: Not applicable  
Origin Mark: VENTCROFT

### PERMISSIBLE MARKS



# BASEC

YELLOW  
ACETATE  
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 07/12/2010

COPY  
21/11/2008



Signed for and on behalf of the British Approvals Service for Cables

Date

19/11/2008



004