

Product Certification Schedule

Schedule No: 152/001/001
Licensee: VENTCROFT LIMITED, GODDARD ROAD, ASTMOOR INDUSTRIAL ESTATE, RUNCORN, CHESHIRE, WA7 1NQ,
Factory: VENTCROFT LIMITED, GODDARD ROAD, ASTMOOR INDUSTRIAL ESTATE, RUNCORN, CHESHIRE, WA7 1NQ
Specification: BS 7629-1:1997 Incorporating Amendment Nos. 1 & 2 - Specification for 300/500V fire resistant electric cables having low emission of smoke and corrosive gases when affected by fire. Part 1. Multicore cables.
Type of Cable: Table 2 - Multicore cables
HAR Document: Not applicable
HAR Specification: Not applicable
Range of Approval: 1.0sqmm to 4sqmm nominal cross-sectional area of conductors inclusive. Twin-core to 4-core inclusive. Sheath - LTS3. Insulation - EI2.
Origin Thread: Not applicable
Origin Mark: VENTCROFT

PERMISSIBLE MARKS



BASEC

YELLOW
ACETATE
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 07/12/2010

COPY
21/11/2008



Signed for and on behalf of the British Approvals Service for Cables

Date

19/11/2008



004